



Control Number: 50595



Item Number: 167

Addendum StartPage: 0




Public Utility Commission of Texas

COPY

Employee Training Report

Required by 16 Texas Admin. Code § 25.97(d)

PROJECT NO. 49827



AFFECTED ENTITY: City of Hallettsville

General Information

Pursuant to 16 Texas Admin. Code § 25.97(d)(2), not later than the 30th day after the date an affected entity finalizes a material change to a document or training program, the affected entity must submit an updated report. The first report must be submitted not later than May 1, 2020.

Instructions

Answer all questions, fill-in all blanks, and have the report notarized in the Affidavit.

Affidavit

A representative of the affected entity must swear to and affirm the truthfulness, correctness, and completeness of the information provided by attaching a signed and notarized copy of the Affidavit provided with this form.

Filing Instructions

Submit four copies (an original and three copies) of the completed form and signed and notarized Affidavit to:

Central Records Filing Clerk
Public Utility Commission of Texas
1701 N. Congress Avenue
P.O. Box 13326
Austin, Texas 78711-3326
Telephone: (512) 936-7180

167

1. Provide a summary description of hazard recognition training documents you provide your employees related to overhead transmission and distribution facilities.

Power point presentatin given by Hi-Line Engineering and provided by Texas Electric Cooperatives.

2. Provide a summary description of training programs you provide your employees related to the National Electrical Safety Code for construction of electric transmission and distribution lines.

Power point presentation given by Hi-Line Engineering and provided by Texas Electric Cooperatives.

Affected Entity: City of Hallettsville

PROJECT NO. 49827

AFFIDAVIT

I swear or affirm that I have personal knowledge of the facts stated in this report or am relying on people with personal knowledge, that I am competent to testify to them, and that I have the authority to submit this report on behalf of the affected entity. I further swear or affirm that all statements made in this report are true, correct, and complete.

Grace Ward
Signature

Grace Ward
Printed Name


City Administrator/Secretary
Job Title

City of Hallettsville
Name of Affected Entity

Sworn and subscribed before me this 1st day of May, 2020
Month Year


Francis Bock
Notary Public in and For the State of TEXAS

My commission expires on 5-6-2024



City of Hallettsville Project 49827 Training Documents.

These documents were omitted in the original Employee training report
Required by 16 Texas Admin. Code 25.97(d)




GDS Associates, Inc.
ENGINEERS & CONSULTANTS

**POWER LINE SAFETY BILL
HB 4150**

KEVIN J. MARA, P.E.
KEVIN.MARA@GDSASSOCIATES.COM, CELL - (678) 488-4691

1



AGENDA

- ❑ History of HB 4150
- ❑ Training Requirements
 - Hazard Recognition
 - NESC
- ❑ Five Year Reporting
- ❑ Annual Reporting of Non-Compliant Transmission Lines
- ❑ Annual Report of Fatalities or Injuries
- ❑ Inspection of Distribution and Transmission Lake Crossings
- ❑ Cost Recovery

2

HISTORY

- ❑ August 5, 2017, three Boy Scouts were electrocuted when the topmast of their sailboat struck a low power line strung across Lake O' the Pines.
- ❑ HB 4150 passed on a vote of 143-0.
- ❑ State Rep. Chris Paddie
"Ultimate goal is to ensure that no family has to experience what they experienced."

3

PURPOSE OF THE HB 4150

- ❑ Power Line Safety Act
 - Requires all utilities that own or operate transmission line to train employees to recognize safety problems.
 - Resulted in new rules passed by the Texas Public Utility Commission
- ❑ Supported by industry groups

4

POWER LINE SAFETY BILL

- ❑ Cost allocation
- ❑ T&D lines must be in compliance with the NESC
- ❑ Report on training
- ❑ Report on inspection of transmission (> 60 kV)
- ❑ Report on non-compliance
- ❑ T&D lines over lakes not in compliance shall be corrected by December 2021
- ❑ Reports due by May 2020

5

TEXAS PUBLIC UTILITY COMMISSION

- ❑ Developed rules for implementation of the HB 4150
- ❑ Public Utility Regulatory Act (PURA) §38.102
- ❑ Order adopting the new rule dated February 14, 2020
 - see Texas PUC website Project 49827

6

TRAINING REQUIREMENTS

- ❑ §38.102 Applies to electric utility, municipally owned utility, and electric cooperative that owns or operates overhead transmission or distribution assets
- ❑ Transmission means facilities greater than 60 kV

7

TRAINING REQUIREMENTS

§38.102 Submit report to PUC with a summary description of

1. Hazard recognition training to its employees related to overhead transmission and distribution facilities
2. Training programs to employees related to NESC for construction of T&D lines

8

TRAINING REQUIREMENTS

- ❑ "to employees"
- ❑ NESC for the construction of T&D lines
 - Line personnel and engineers
- ❑ Hazard recognition training
 - Not well defined as which employees
 - Line personnel and engineers have a basis of understanding
 - How about other employees such as vegetation management and substation technicians?
 - Office personnel?

9

HAZARD RECOGNITION TRAINING

- ❑ Underlying goal is to report problems so corrections can be made.
- ❑ Personnel need to be able to recognize that there is a problem
 - Requires basic knowledge of the overhead system
- ❑ Consider training personnel who have skill sets to report problems with overhead power lines

10

HAZARD RECOGNITION TRAINING



- ❑ One of the root causes of workplace injuries and incidents is failure to identify or recognize the hazard.
 - Critical element is ability to identify and assess the hazard.
- ❑ OSHA 1926.21(b)(2)
 - Employers shall instruct each employee in the recognition and avoidance of unsafe conditions

11

HAZARD RECOGNITION TRAINING




- ❑ The goal of Power Line Safety Act is prevent power line clearance issues
 - Public Safety
 - Public is not expected to know safe distances
- ❑ Hazard Recognition training focuses on power line clearance issues
 - Identify and assess unsafe conditions
 - Non-compliance with NESC
 - Watch for strength issues and danger trees

12

HAZARD RECOGNITION TRAINING


- ❑ Training is not OSHA 1926(b)(2) requirement for employees related hazards at the worksite
- ❑ Unique training related to inspection and observation of lines when driving by or working nearby.



13

NESC TRAINING


- ❑ Training programs to employees related to NESC for construction of T&D lines.
- ❑ The bill used the word "construction" and not "clearances".
 - PUC declined to limit the scope of training to be only vertical clearances (49827-36)
- ❑ Clearly the goal is public safety
 - NESC Rule 010 – these rules are necessary for safeguarding the public



14

NESC TRAINING

- ❑ Focus on clearances (vertical and horizontal)
- ❑ Need to include adders for transmission clearances
 - Voltages exceeding 22kV (phase to ground)
 - 0.4 inches per kV over 22kV
 - Adjustments for elevation and maximum operating voltages



15

TRANSMISSION ADJUSTMENTS

- ❑ Can the transmission trip for single-line to ground faults?
- ❑ Voltage adder
 - 69kV requires 19.2 feet above a road
 - Add 5% for voltage range
 - 72.45kV (69×1.05) requires 19.9 feet
 - 115kV requires 20.0 feet above a road
 - Add 5% for voltage range
 - 115kV \times 1.05 requires 20.2 feet above a road

16


TRANSMISSION ADDERS

- Add for elevations over 3,000 feet above sea level



17

NESC TRAINING




- Roads
- Lakes
- Buildings
- Other structures
- Grain bins/pools

18

TRANSMISSION STRUCTURES

- ❑ Rule 234B
- ❑ Wind displacement with 50 MPH wind at 60F.
- ❑ Include deflection of suspension insulators
- ❑ Include deflection of a flexible structure if the cable is attached 60 ft or more above grade



19

NESC TRAINING

- ❑ Other topics that could be covered
 - Grounding, and missing neutrals
 - Pole and guy strength
 - Clearance between conductors
 - Substation security

20

TRAINING DOCUMENTATION

- ❑ File summary of training with PUC
- ❑ If and when an incident occurs
- ❑ How to show your employees have been trained?
 - Sign-in sheets
 - Testing – provides confirmation of understanding
 - On-line testing for record retention

21

TRANSMISSION LINE SAFETY

- ❑ §38.102(c) May 1, 2020 each electric utility, municipally owned utility and electric cooperative that owns or operates transmission facilities greater than 60 kV shall submit to the PUC a report
 - Percent of transmission line inspected for vertical clearance in the last 5 years
 - Percent of transmission line to be inspected for vertical clearance in the next five years

22

TRANSMISSION LINE INSPECTION

- ❑ §38.102(c) May 2020 Filing, filing once every 5 years
 - Miles of transmission line owned or operated
 - Percentage of transmission line inspected for compliance with NESC **Vertical Clearance** for the years 2015-2019
 - PUC noted some utilities may find it challenging to provide the required information, but the utilities should make efforts to accurately report the information.

23


TRANSMISSION LINE INSPECTION

- ❑ Inspections for 2015-2019
- ❑ Note "patrol" inspection based on right-of-way cycle
 - Observation without measurements
 - From a truck or on foot
- ❑ Note "pole inspections" based on transmission pole inspections, if vertical clearance was in the scope of the inspectors
- ❑ Note any other inspections such as LiDAR

24

TRANSMISSION LINE INSPECTION

- ❑ §38.102(c)(2)
May 2020 Filing, once every five years
 - Percentage of transmission lines inspected compliance with NESC **Vertical Clearance** for the years 2020-2024



25

TRANSMISSION LINE INSPECTION

- ❑ Cycle for inspection not specified
 - 5 year cycle implied but not required
- ❑ Method for inspection not provided to determine compliance with NESC vertical clearance
- ❑ Rating of the conductor
 - 75°C or 167°F
 - Actual tension
- ❑ LiDAR inspection
- ❑ Ground observation
- ❑ Survey methods

26

ANNUAL REPORT REQUIREMENTS

- ❑ §38.102(d) No later than May 1 every five years
- ❑ Submit a report for the preceding year
 - Number of identified occurrences of noncompliance with PURA §38.004
 - Compliance with clearances set forth in NESC in effect at the time of construction.
 - Includes crossings over the 173 Texas lakes listed

27


ANNUAL REPORT REQUIREMENTS

- ❑ §38.102(c)(1) Report if the utility has actual knowledge of any portion of the transmission facilities not in compliance with vertical clearance requirements of the NESC.
 - Did you learn of any low clearances last year?
 - Did you replace transmission poles with taller poles?
 - Distribution under-build on transmission line can cause the transmission structure to be non-compliant.

28

ANNUAL REPORT REQUIREMENTS

- §38.102(c)(3) Report for last year, if the utility has actual knowledge of any violations of easement agreements with the Corps of Engineers regarding vertical clearance of transmission line as required by the NESC.
 - Corps of Engineers often has vertical clearances greater than NESC.
 - Find your existing permits



US Army Corps
of Engineers®

- 

29


LAKE CROSSING		Table 232-1— (continued)			
		Vertical clearance of wires, conductors, and cables above ground, roadway, rail, or water surfaces			
		(Voltages are phase to ground for effectively grounded circuits and those other circuits where all ground faults are cleared by properly de-energizing the limited section, both initially and following subsequent breaker operations. See the definitions section for voltages of other systems.			
		See Rules 232A, 232B1, 232C1a, and 232D4.)			
Number of service conductors, wires, conductors, or cables	In related transmission lines conductors and cable, unenergized; overhead should never go over the water; other city, go around port, ungrounded portions of port (moving Rule 215C2 and 279A3) reported in 10 ft above of conductors moving Rule 230E1; supply cables moving Rule 230C1 (B)	Non-energized transmission lines (conductors); supply cables of 0 to 750 V (moving Rule 230C1 and 230C3) (D)	Supply cables are 750 V (moving Rule 230C2 or 230C3); extra supply conductors, 0 to 750 V; ungrounded portions of port (moving Rule 215C2 and 279A3) reported in 10 ft above of 750 V (232B1) (E)		
Name of service conductors, wires, conductors, or cables		Trolley and overhead railroad contact conductors and associated span or messenger wires			
		8 to 750 V to ground (F)			
		Over 750 V to ground (G)			
If any area is suitable for swimming including lakes, ponds, rivers, creeks, streams, and canals with no submerged surface area of					
a. Less than 20 acres		17.5	18.5		
b. Over 20 to 200 acres		23.7	24.5		
c. Over 200 to 2000 acres		31.3	32.3		
d. Over 2000 acres		37.7	40.5		
e. Established boat ramps and associated staging areas, areas used with respect to the fishing and boating		Clearance above ground shall be 5 ft greater than in f above, for the type of water area served by the launching site.			

- | Name of water conductor, or cable | Insulated transmission lines conductors and cables, unarmored, or if shield should wrap per section 240-1; unless the dry ground part, ungrounded portions of open crossing Rules 215C2 and 276A1 exposed in 0 to 300 V | Unarmored transmission lines conductors; supply cables of 0 to 750 V; ungrounded portions of open crossing Rules 215C2 and 276A1 exposed in 0 to 300 V | Supply cables over 750 V moving Rules 230C2 or 230C3; open supply conductors, or 0 to 750 V ungrounded portions of open crossing Rules 215C2 and 276A1 exposed in 0 to 300 V | Open supply conductors, or 0 to 750 V in 21 kV or ungrounded portions of open crossing Rules 215C2 and 276A1 exposed in 21 kV or 22 kV | Trolley and overhead 15 kV and over conductors and even when open or unarmored wires | 0 to 750 V or ground (ft) | Over 750 V or 22 kV or ground (ft) |
|-----------------------------------|---|--|--|--|--|---------------------------|------------------------------------|
| 1. Less than 20 acres | 17.1 | 18.0 | 18.3 | 20.5 | — | — | |
| 2. Over 20 to 200 acres | 25.1 | 29.0 | 26.5 | 28.5 | — | — | |
| 3. Over 200 to 2000 acres | 31.1 | 33.0 | 32.5 | 34.5 | — | — | |
| 4. Over 2000 acres | 37.1 | 38.0 | 38.5 | 40.5 | — | — | |
5. Established best crops and associated irrigating areas, areas planted with sugar- or rice irrigated by handwork and bores
- Classroom observation shall be 5 ft greater than 0 ft distance for the type of water area served by the launching site

30

LAKE CROSSING

- Footnote 20
- Bridge limitations on water area



Power line on small lake side of bridge

31

CORP OF ENGINEERS

- Reference Pool Elevation
 - 249.5' for Lake of the Pines
 - Reference pool elevation is the elevation of the spillway crest.

	751V- 22kV	23kV- 87KV	88kV- 115kV	116kV- 161kV
COE in Ft	56.5	58.7	59.6	61.1
NESC for 2,000 Acre Lake in Feet	40.5	41.5	42.1	43

Check with COE!!

32

ANNUAL REPORT REQUIREMENTS

- ❑ §38.102(e) Each year by May 1, utility must report for the prior year,
- ❑ For transmission and distribution facilities
 - Distribution being defined as greater than 1 kV
- ❑ Number of fatalities or injuries other than employee, contractors or other persons qualified to work in proximity of head high voltage lines
- ❑ Report of these injuries is limited only to those facilities that are found noncompliant with the NESC.

33

ANNUAL REPORT REQUIREMENTS

- ❑ Reporting on public contact with lines that are not compliant.
- ❑ Contact with lines that are compliant is not required.

34

ANNUAL REPORT REQUIREMENTS


- ❑ For reported injuries and fatalities prior description of corrective action taken to prevent reoccurrence.
- ❑ PURA §38.102 states that reports made are not admissible in a civil or criminal proceeding against the electric utility.

35

ANNUAL FILING REQUIREMENTS

- ❑ Violations from a national disaster, weather event, or man-made act or force outside of affected utility's control are not required to be reported
- ❑ Crane contacting power line that is compliant need not be reported
 - Check with legal counsel

Crane / Derrick Transmission Clearance



Crane / Derrick	Less than 50kV	Heavy machinery equipment (backhoes, front-end loaders, bulldozer, dump trucks)	Less than 50kV
Must Contact Electric Utility if maximum working radius in the work zone. See OSHA 1926.1408 (a) (2)	20 feet	Horizontal Minimum Clearance from See OSHA 1926.500 (a) (5)	10 feet
Minimum Approach Distance ONLY if Specific Controls in Place See OSHA 1926.1408 (a) (2) (iii)	10 feet	Vertical Minimum Clearance from See OSHA 1926.500 (a) (5)	10 feet

36

ANNUAL FILINGS


- ❑ The commission will make all reports publicly available by September 1 of each year.

37


HB 4150 CLEARANCE OVER LAKES

- ❑ Electric utilities, municipally owned utilities, and electric cooperatives with a transmission or distribution line over one of the 178 Texas lakes listed in HB4150

38



39



40

HB 4150

- ❑ Any electric utility who owns a transmission or distribution line over a lake listed in Section 38.004(b),
 - And that line is not in compliance with the clearance standards of NESC Rule 232 in effect at the time the line was constructed
 - Shall bring the line into compliance not later than December 31, 2021.
- ❑ Per HB 4150 any lines rebuilt, must be compliant with the current NESC (no grandfathering)
- ❑ Beware that the NESC and COE have different requirements for clearances over the lake. COE is the controlling entity.

41

LAKE CROSSINGS

- ❑ Inspection lake crossing in 2020
- ❑ Plan to correct by end of 2021
 - Update COE permits may slow the process
- ❑ New NESC requires Grade B strength
- ❑ Date of correction is not contained in PUC requirements

42


LAKE CROSSINGS

- ❑ Many different ways to attack the problem
- ❑ LiDAR
- ❑ Survey

43

LAKE CROSSING

- ❑ Obtain benchmark/elevation of full pool
- ❑ Elevation of base of the pole on each side
- ❑ Horizontal distance
- ❑ Determine attachment height



44

- [illegible]

Lake Crossing

Conductor: 336.4 Kcmil 18/ 1 Stranding ACSR "MERLIN"

Area = 0.2789 Sq. in Diameter = 0.684 in Weight = 0.365 lb/ft RTS = 8680 lb

Data from Chart No. 1-844

English Units

Limits and Outputs in Average Tensions.

Span = 664.0 Feet Special Load Zone

Creep IS a Factor Rolled Rod

Design Points				Final			Initial	
Temp °F	Ice in	Wind psf	K lb/ft	Weight lb/ft	Sag Ft	Tension lb	Sag Ft	Tension lb
15.0	0.25	4.00	0.20	0.965	13.73	3880	13.11	4062
32.0	0.25	0.00	0.00	0.655	12.67	2855	11.17	3237
0.0	0.00	0.00	0.00	0.365	8.39	2399	6.67	3016
15.0	0.00	0.00	0.00	0.365	9.28	2170*	7.25	2776
30.0	0.00	0.00	0.00	0.365	10.19	1976	7.90	2547
60.0	0.00	0.00	0.00	0.365	12.02	1675	9.40	2142
90.0	0.00	0.00	0.00	0.365	13.80	1460	11.07	1819
120.0	0.00	0.00	0.00	0.365	15.49	1302	12.79	1575
167.0	0.00	0.00	0.00	0.365	17.93	1125	15.41	1309

* Design Condition

23

Lake Crenshaw
Neutral without Marker Balls

Conductor: # 7/ AWC 6/ 1 Stranding ACSP "QUAIL"

Area = 0.1271 Sq. in.

Data from Chart No. 1-938

English Unit

Limits and Outputs in Average Tension*

Diameter = 0.447 in.

Weight 183 lb/ft (RT) 531 lb

Span 664.1 Feet

Temperature Factor: 1.00

Special Load Zone

Polled Rod

Design Points				Final		Initial	
Temp °F	Ice in	Wind psf	Weight lb/ft	Weight lb/ft	Final Tension lb	Stg Tension lb	Initial Tension lb
0.0	0.00	0.00	0.00	0.183		7	1137
15.0	0.00	0.00	0.00	0.183		9.55	1054
30.0	0.00	0.00	0.00	0.183		10.22	987
40.0	0.00	0.00	0.00	0.183		11.66	866
50.0	0.00	0.00	0.00	0.183		13.11	771
120.0	0.00	0.00	0.00	0.183		14.54	695

Above: Initial Data Prior to Marker Ball Installation

Below: Marker Ball Installation

Temp °F	Ice in	Wind psf	Weight lb/ft	Weight lb/ft	Final Tension lb	Stg Tension lb	Initial Tension lb
15.0	0.00	0.00	0.200	0.435	15.47	2055	19.17 1655*
30.0	0.25	0.00	0.00	0.630	17.97	193	10.95 254
40.0	0.00	0.00	0.00	0.260	12.95	11.7	10.93 134
50.0	0.00	0.00	0.00	0.260	13.67	1044	11.22 127
60.0	0.00	0.00	0.00	0.260	14.38	957	11.83 1212
120.0	0.00	0.00	0.00	0.260	15.77	810	13.08 150
120.0	0.00	0.00	0.00	0.260	17.11	30	4.35 150
120.0	0.00	0.00	0.00	0.260	17.11	7.1	15.62 119

* Design condition

47

<ul style="list-style-type: none"> Requires 95 foot pole Only 55 foot in place Difficult to determine existing tension Return wave difficult Model actual pole and clearance at 60°F Existing ground clearance per the model 	
--	--

48

LIDAR


- ❑ Fly over with Drone
- ❑ Provides actual tensions
- ❑ Faster verification of clearance
- ❑ Mobilization expensive need to do several at a time

49

INITIAL SCREENING

- ❑ Use Google Earth
 - Rough elevations
 - Pole heights
 - Sag tables for the specific span

50



51

ASSIGNMENT OF COSTS

- ❑ "Costs incurred by a municipally owned utility or electric cooperative to comply with Section 38.102 [i.e., new reporting requirements] shall be recorded as a regulatory asset for timely recovery in wholesale transmission rates established by the commission."

52

ASSIGNMENT OF COSTS

- ❑ "recovery in wholesale transmission rates established by the commission"
- ❑ These costs will ERCOT wholesale transmission charges through Transmission Cost of Service rate filing
- ❑ Commenters on the new rule asked for clarification regarding items eligible for expense recovery and which rate mechanisms are the appropriate vehicle to request recovery.
 - Commission declined to address cost recovery in this rulemaking

53

ASSIGNMENT OF COSTS


- ❑ Upgrade costs will be capital expenditures
- ❑ Record the following costs
 - Mandated training
 - Mandated inspection
 - Mandated reporting
- ❑ There may be future rule making or the first utility in for TCOS reveal PUCT acceptance of costs.

54

WHAT NOW?

- ❑ 5 Year Reporting
 - Vertical inspection of transmission for 2015-2019
 - Future inspection – what is your plan?
- ❑ Annual Reporting
 - Known non-compliant T-lines and corrective actions
- ❑ Annual Reporting of fatalities or injuries
- ❑ Training program descriptions
 - Training is required but not before May 2020
- ❑ Review lake crossings in 2020 and fix in 2021

55



56